



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-14-00315 OWNER'S NAME: QUITADAMO  
DATE: 11/19/2014 TYPE: Exterior shear  
TIME STARTED: 10:44 AM INSPECTOR: Amber Green  
MAP NUMBER: 18-17-36051-0016

	1. Portal frames at garage wall to have (2) 2x plates at sill.

**INSTRUCTIONS:** Add second plate and roto two anchor bolts. Nail sheathing to both plates. Will see at framing inspection. Ok to Cover once complete.

**NEXT INSPECTION:** Frame/Plumb/Mech

**RE-INSPECTION FEE DUE?** ☒ NO ☐ YES \$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

amber.green @co.kittitas.wa.us

• **INSPECTION REQUEST LINE:** [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •  
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506