

KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-14-00315	OWNER'S NAME:	QUITADAMO
DATE:	1/20/2015	TYPE:	Re-inspection
TIME STARTED:	9:54 AM	INSPECTOR:	Jessica Contratto
	18-17-36051-0016		

1. complete draftstop and seal chimney at penetration		
2. support verical insulation near chimney		

INSTRUCTIONS: complete above, call for re-inspection

NEXT INSPECTION:

RE-INSPECTION FEE DUE?

NO NO

YES

ES

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

jessica.contratto @co.kittitas.wa.us

\$

• INSPECTION REQUEST LINE: <u>www.co.kittitas.wa.us/cds/request.asp</u> or 509-962-7694 • 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506