



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00376 OWNER'S NAME: BLAIS/REDMOND
DATE: 1/29/2015 TYPE: Frame-Plumb-Mech
TIME STARTED: 11:25 AM INSPECTOR: Jeremy Haberman
MAP NUMBER: 20-16-24000-0017

	1. Trusses OK.
	2. Framing OK.
	3. DWV OK. 5#/15min.
	4. Gas OK. 24#/15min.
	5. H2O Supply OK. 52#/15Min.
	6. Aux. Drain for Attic Furnace to Terminate in Conspicuous Area. Verify at Insulation.

INSTRUCTIONS: Complete Corrections Above

NEXT INSPECTION: Insulation.

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506