



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00397 OWNER'S NAME: CAREY
DATE: 7/10/2015 TYPE: Exterior shear
TIME STARTED: 11:49 AM INSPECTOR: Jeremy Haberman
MAP NUMBER: 21-14-34061-0004

	1. Window In Shear Wall at Up Stairs Closet Not Per Plan. Get Engineer OK.
	2. Double Check All W6 Shearwall Nailing.

INSTRUCTIONS: Make Corrections Above

NEXT INSPECTION: Re Inspect Shear.

RE-INSPECTION FEE DUE? ☒ NO ☐ YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506