



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-14-00397

OWNER'S NAME: CAREY

DATE: 9/14/2015

TYPE: Mechanical and plumbir

TIME STARTED: 3:59 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 21-14-34061-0004

	1. Plumbing OK. DWV on Stack. Supply Live Test.
	2. Mechanical Venting and Supply OK.
	3. Freestanding Fireplace Rough in Insulation Collar OK.
	4. Gas Line Not on Test.
	5. NOTES FOR FRAMING: Provide Engineers Correction LETter for BCI Modifications, Provide
	eadar Call Outs, Fire Block Stairwells, Retaining Walls Over 4' Require Engineering.

INSTRUCTIONS: Make Corrections Above.

NEXT INSPECTION: Framing.

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ jeremy.haberman @co.kittitas.wa.us

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506