



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-14-00397

OWNER'S NAME: CAREY

DATE: 9/17/2015

TYPE: Re-inspection

TIME STARTED: 3:58 PM

INSPECTOR: Jessica Contratto

MAP NUMBER: 21-14-34061-0004

	1. BCI correction received
	2. gas at 16#-ok
	3. deck attachment ok
	4. still need engineer fix for blocking in basement
	5. engineering still required for retaining wall

INSTRUCTIONS: ok to insulate, see blocking correction before cover

NEXT INSPECTION: insulation

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506