



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00400 OWNER'S NAME: NEW SUNCADIA LLC
DATE: 9/30/2014 TYPE: Exterior shear
TIME STARTED: 2:53 PM INSPECTOR: Amber Green
MAP NUMBER: 20-15-29051-0015

	1. Nail sheathing into both bottom plates per detail at garage P1-6 panels at front.
	2. Provide OK from truss engineer at framing inspection for plumbing cut at bottom chord.
	3. DWV (H20/15min) - OK
	4. H2O (working pressure) - OK

INSTRUCTIONS: Complete #1, then OK TO COVER.

NEXT INSPECTION: FRAME/PLUMB/MECH

RE-INSPECTION FEE DUE? ☒ NO ☐ YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ amber.green @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506