INSPECTION REPORT

PERMIT NUMBER:	BP-14-00400	OWNER'S NAME:	NEW SUNCADIA
DATE:	11/4/2014	TYPE:	Insulation
TIME STARTED:	11:34 AM	INSPECTOR:	Lou Whitford
MAP NUMBER:	20-15-29051-0015		
1. OK FF	RAMING CORRECTIONS	 S	
2. OK IN	SULATION		
3. OK WINDOWS .27 U-VALUE			
4. NOTE; OPTION 1a REQUIRES R-38 FLOOR INSULATION			
5. NOTE	: FLOOR FIRE SEPERA	TION AT GAR	AGE BY FINAL
INSTRUCTIONS:			
NEXT INSPECTION: FINAL			
RE-INSPECTION FEE	DUE? NO YES		\$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:			
lou.whitford @co.kittitas.wa.us			
 INSPECTION REQUEST LINE: <u>www.co.kittitas.wa.us/cds/request.asp</u> or 509-962-7694 ◆ 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 ◆ Main Office Line: 509-962-7506 			