



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00400

OWNER'S NAME: NEW SUNCADIA LLC

DATE: 5/4/2015

TYPE: Final

TIME STARTED: 12:08 PM

INSPECTOR: Jessica Contratto

MAP NUMBER: 20-15-29051-0015

	1. maintain fire separation at furnace area floor
	2. water heater does not meet .63 EF minimum for efficiency credit
	3. hand rail not installed at back deck stairs
	4. lavatory faucets to be 1.0 GPM
	5. all other items ok for final
	6. verify fire marshal final and Suncadia sewer approval

INSTRUCTIONS: complete above

NEXT INSPECTION: re-inspection

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506