



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00401

OWNER'S NAME: SCHEMM

DATE: 12/18/2014

TYPE: Rough-in plumbing

TIME STARTED: 12:04 PM

INSPECTOR: Jessica Contratto

MAP NUMBER: 20-14-24050-0206

	1. H2O at 150#/15-ok
	2. DWV on stack-ok

INSTRUCTIONS: rough in plumbing ok

NEXT INSPECTION: frame/mech/re-shear

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jessica.contratto @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506