



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00401 OWNER'S NAME: SCHEMM
DATE: 4/21/2015 TYPE: Insulation
TIME STARTED: 9:32 AM INSPECTOR: Jeremy Haberman
MAP NUMBER: 20-14-24050-0206

	1. Fireplace Enclosures Not Complete. Leave Open.
	2. Insulation OK.
	3. Interior Shear OK.
	4. Can Lights in the Garage Non Fire Rated. Contractor to Install Shroud. Photograph to be Provided.

INSTRUCTIONS: OK to Cover.

NEXT INSPECTION: Fireplace. Exterior Gas Lines.

RE-INSPECTION FEE DUE? ☒ NO ☐ YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506