



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00401

OWNER'S NAME: SCHEMM

DATE: 4/23/2015

TYPE: Stove or fireplace

TIME STARTED: 12:05 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-14-24050-0206

	1. Complete flue for downstairs fireplace on mainfloor
	2. Provide 20" hearth extension in front of main floor fireplace per manual
	3. Manual page 13 note A requires a concrete support slab for the firebox and wood underpi
	nning is not allowed
	4. Do not cover

INSTRUCTIONS: Do not cover/Provide installation per Manufacturers Installation Manual & Engineering for additional dead load required/Make corrections above/Re-inspection

NEXT INSPECTION: Re-inspection

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

justin.bennett @co.kittitas.wa.us

• **INSPECTION REQUEST LINE:** www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506