



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00431

OWNER'S NAME: MOORE

DATE: 7/28/2014

TYPE: Slab plumbing

TIME STARTED:

INSPECTOR: Jessica Contratto

MAP NUMBER: 18-18-18000-0003

	DWV in stack-OK
	complete slab insulation

INSTRUCTIONS: complete above. Ok to pour slab

NEXT INSPECTION: shearwalls

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jessica.contratto @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506