INSPECTION REPORT

PERMI	T NUMBER:	BP-14-00436	OWNER'S NAME:	SAVIO	
DATE:		5/13/2015	TYPE:	Insulation	
TIME STARTED:		10:04 AM	INSPECTOR:	Justin Bennett	
MAP NUMBER:		21-14-16052-0002			
	1. Correction	ction 7 verified blocking at stairs - Ok			
	2. Correction 8 wood stove deleted - Ok				
	3. Correction 9 Plumbing @ 80#/15 mins - Ok				
	4. Correction 10 Gas piping at 60#/15mins - ok				
	5. Complete remaining corrections				
	6. Insulation Ok				
	7. Ok to cov	7. Ok to cover			
INSTRUCTIONS: Verify corrections at Final/Ok to cover					
NEXT INSPECTION: Final					
RE-INSPECTION FEE DUE? VES \$					
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION					
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:					
	iustin.bennett @co.kittitas.wa.us				
 INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 Main Office Line: 509-962-7506 					