



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-14-00436

OWNER'S NAME: SAVIO

DATE: 6/10/2016

TYPE: Final

TIME STARTED: 10:46 AM

INSPECTOR: Jessica Contratto

MAP NUMBER: 21-14-16052-0002

1. Propane sniffer alarm not installed in garage for water heater
2. Fuel tank placement not signed off
3. Tempered window film on loft windows-ok
4. Log posts in garage need to be wrapped in drywall
5. Recessed can light penetrations not allowed in fire separation. Must be removed or a UL listed fire "cover" must be installed over the light per manufacturer's instructions
6. WUIC final not signed off
7. Other prior corrections ok
8. Road certification needs to be submitted prior to final
9. Door from garage to residence to be self closing

INSTRUCTIONS: Complete above, re-inspect

NEXT INSPECTION: Re-inspection

RE-INSPECTION FEE DUE? ☒ NO ☐ YES \$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: jessica.contratto @co.kittitas.wa.us

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506