



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00449

OWNER'S NAME: SINNETT

DATE: 3/2/2015

TYPE: Rough-in plumbing

TIME STARTED: 10:23 AM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-14-14050-0925

	1. Laundry DWV OK. 5#/15min.
	2. Mechanical DWV not at Pressure. 2 PSI observed at time of inspection
	3. Supply OK. 70#/15min.

INSTRUCTIONS: Complete Above.

NEXT INSPECTION: Plumbing ReInspect.

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506