



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-14-00449

OWNER'S NAME: SINNET

DATE: 6/4/2015

TYPE: Multiple (see notes)

TIME STARTED: 4:55 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-14-14050-0925

	1. Interior Gas Line OK. 15#/15min.
	2. Exterior Gas Line Sleeve Tentatively OK.

INSTRUCTIONS: Further Inspection Required on Actually Lines Exterior

NEXT INSPECTION: Framing

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ [jeremy.haberman@co.kittitas.wa.us](mailto:jeremy.haberman@co.kittitas.wa.us)

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506