



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-14-00449

OWNER'S NAME: SINNETT

DATE: 7/8/2015

TYPE: Stove or fireplace

TIME STARTED: 10:30 AM

INSPECTOR: Jessica Contratto

MAP NUMBER: 20-14-14050-0925

	1. truss correction complete on 1 truss. Continue and send pics when complete
	2. tighten up draftstop at masonry fireplace around ductwork
	3. draftstops/fireplace install ok

INSTRUCTIONS: ok to cover interior after corrections. See additional support for masonry fireplace in crawl

NEXT INSPECTION: burial gas pipe, masonry fireplace framing and support

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506