



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00449

OWNER'S NAME: SINNET

DATE: 1/21/2016

TYPE: Final

TIME STARTED: 1:43 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-14-14050-0925

	1. All Outstanding Corrections OK.
	2. Plumbing and Mechanical Final OK.
	3. Insulate Floor to R-38 then Energy Credits Met. OK. Provide Certificate.
	4. Provide Blower Door Test Report. Must be less than 4.0 for Energy.
	5. Provide Sewer Letter.
	6. Provide Water Heater/Furnace Documentation.

INSTRUCTIONS: Email Documentation, if OK, then Provide Card to CDS.

NEXT INSPECTION: Final

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506