



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00491 OWNER'S NAME: CRAIG REIMER
DATE: 2/26/2015 TYPE: Exterior shear
TIME STARTED: 11:29 AM INSPECTOR: Justin Bennett
MAP NUMBER: 20-15-29051-0100

	1. Provide 3x bottom plate on P1-3 in garage
	2. Nail sill plate per shear wall schedule
	3. Install hold down garage

INSTRUCTIONS: Complete items above/Exterior Shear Ok

NEXT INSPECTION: Framing

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

justin.bennett @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506