



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00491 OWNER'S NAME: REIMER
DATE: 3/26/2015 TYPE: Gas piping
TIME STARTED: 1:02 PM INSPECTOR: Jeremy Haberman
MAP NUMBER: 20-15-29051-0100

	1. Gas Line OK. 15#/15/min.
	2. DWV OK. 5#/15/Min.
	3. Supply OK. 60#/15/min.
	4. Kitchen Sink Supply and Drain Not Installed at Time of Inspection.
	5. Fireplace Draft Stop Not Complete. Fireplve Not Installed.
	6. Upstairs Bath Fan Exhaust Not Terminated.
	7. Upstairs Supply Trunk Not Insulated.
	8. Shearwall Corrections OK.

INSTRUCTIONS: Complete Above Prior to Cover

NEXT INSPECTION: Framing.

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506