



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-14-00491 OWNER'S NAME: CRAIG REIMER CUSTOM HOMES  
DATE: 3/27/2015 TYPE: Framing  
TIME STARTED: 1:09 PM INSPECTOR: Jessica Contratto  
MAP NUMBER: 20-15-29051-0100

	1. truss bracing K2, H2,
	2. additional permitting for added sink in bonus room
	3. nail plates where needed
	4. nail outlookers into blocking
	5. inverted hangers needed on master bed ceiling overhang per plan
	6. Studor vents not permitted. Different venting needed for island
	7. fireplace not installed
	8. interior shear ok

INSTRUCTIONS: ok to insulate walls and vault areas, see corrections then

NEXT INSPECTION: insulation/fireplace

RE-INSPECTION FEE DUE? ☒ NO ☐ YES \$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

jessica.contratto @co.kittitas.wa.us

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •  
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506