



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-14-00497 OWNER'S NAME: BURNSTEAD  
DATE: 8/26/2014 TYPE: Footings  
TIME STARTED: 1:33 PM INSPECTOR: Amber Green  
MAP NUMBER: 20-15-20059-0021

	1. Spread footings missing at garage wall.
	2. Some spread footings not complete per plan.
	3. Spread footing at interior does not have bearing.

INSTRUCTIONS: Re-check all interior footings. Re-call inspection.

NEXT INSPECTION: Re-footings

RE-INSPECTION FEE DUE? ☒ NO ☐ YES \$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ amber.green @co.kittitas.wa.us

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506