



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00513 OWNER'S NAME: RC TEN LLC
DATE: 1/6/2015 TYPE: Rough-in plumbing
TIME STARTED: 12:39 PM INSPECTOR: Jessica Contratto
MAP NUMBER: 18-18-34058-0002

	1. H2O 85#/15-ok
	2. DWV at 7#/15-ok
	3. P2 shearwalls require 3X panel edge members
	4. A35 clips top plate to blocking missing per shear schedule
	5. tighten up nailing at front west corner
	6. anchor bolts missing at P1 walls

INSTRUCTIONS: fix above or obtain engineer approval. see corrections at framing

NEXT INSPECTION: framing

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jessica.contratto @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506