## **INSPECTION REPORT**

| PERMIT NUMBER:  | BP-14-00534                   | OWNER'S NAME: | TALL BROTHERS DEV LLC |  |
|---|-------------------------------|---------------|-----------------------|--|
| DATE:   | 10/20/2014                    | TYPE:         | Final                 |  |
| TIME STARTED:   | 2:33 PM                       | INSPECTOR:    | Mike Flory            |  |
| MAP NUMBER:   | 17-19-06098-0004              |               |                       |  |
| 1. UNDERFLOOR INSUL NOT IN  |                               |               |                       |  |
| 2. VAPER BARRIER NOT DOWN   |                               |               |                       |  |
| 3. CRAWLSPACE ACCESS COVER NOT IN PLACE   |                               |               |                       |  |
| 4. UNDERFLOOR PIPES NOT INSULATED   |                               |               |                       |  |
| 5. BACKFILL AROUND FOUNDATION NOT COMPLETE  |                               |               |                       |  |
| 6. SEAL GARAGE PENETRATIONS   |                               |               |                       |  |
| 7. COMPLETE ELECTRICAL OR USE COVER PLATES  |                               |               |                       |  |
| 8. HAVE SPRINKLER SYSTEM TESTED BY FIRE MARSHAL (PERMITTED?)  |                               |               |                       |  |
|   |                               |               |                       |  |
|   |                               |               |                       |  |
|   |                               |               |                       |  |
|   |                               |               |                       |  |
|   |                               |               |                       |  |
| INSTRUCTIONS: COMPLETE ABOVE AND RECALL FOR FINAL   |                               |               |                       |  |
|   |                               |               |                       |  |
| NEXT INSPECTION: RE-FINAL   |                               |               |                       |  |
| RE-INSPECTION FEE DUE? NO YES \$  |                               |               |                       |  |
| IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION  |                               |               |                       |  |
| QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:  |                               |               |                       |  |
|   | mike.flory @co.kittitas.wa.us |               |                       |  |
| • INSPECTION REQUEST LINE: <a href="www.co.kittitas.wa.us/cds/request.asp">www.co.kittitas.wa.us/cds/request.asp</a> or 509-962-7694 • 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506 |                               |               |                       |  |