



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00569

OWNER'S NAME: MACY

DATE: 1/29/2015

TYPE: Rough-in plumbing

TIME STARTED: 11:36 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 16-20-03000-0016

	1. Supply at 65#/ 15 mins - ok
	2. DWV @ 3#

INSTRUCTIONS:

NEXT INSPECTION: Re-inspect DWV

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

justin.bennett @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506