



KITTTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

# INSPECTION REPORT

PERMIT NUMBER: BP 14-00576

OWNER'S NAME: Cake Box LLC

DATE: 7.2.15

TYPE: Mechanical/plumbing

TIME STARTED: 10:40 am

INSPECTOR: Green

	Gasline (22#/15min). DWV (H2O/15min) H2O (95#/15min)
	① Complete exhaust fans.
	② web-filter at compromised joists.
	③ Insulate supply ducts in unconditioned space.
	* Fireplace not installed at this time.
	* Range vent installed at later date.

INSTRUCTIONS: Complete move. Can see #3 at insulation.

NEXT INSPECTION: Framing

RE-INSPECTION FEE DUE?  NO  YES \$ 0

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:  
Amber.Green @co.kittitas.wa.us

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •  
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506