INSPECTION REPORT

TYPE:

INSPECTOR:

OWNER'S NAME: BURNETT

Mechanical and plumbir

Justin Bennett

BP-14-00629

7/9/2015

10:20 AM

PERMIT NUMBER:

TIME STARTED:

DATE:

MAP NI	UMBER: 20	15-26063-0014	
	1. Mechanical Ok		
	2. Waste on Stack - Ok		
;	3. Supply @ 70#/15 mins - Ok		
4	4. Plumbing roug	h-in Ok	
INSTRUCTIONS:			
NEXT INSPECTION: Framing			
RE-INSPECTION FEE DUE? VES \$			
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:			
	iustin_bennett @co.kittitas.wa.us		
• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 • 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506			