



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00649

OWNER'S NAME: TERRELL

DATE: 12/5/2014

TYPE: Rough-in plumbing

TIME STARTED: 2:40 PM

INSPECTOR: Amber Green

MAP NUMBER: 16-20-22000-0013

	1. DWV (6#/15min) - OK
	2. H2O (70#/15min) - OK
	3. STHD Straps at garage shear panels OK

INSTRUCTIONS:

NEXT INSPECTION: Exterior Shear

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ amber.green @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506