



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00671

OWNER'S NAME: COLLINS

DATE: 1/8/2015

TYPE: Frame-Plumb-Mech

TIME STARTED: 11:09 AM

INSPECTOR: Amber Green

MAP NUMBER: 19-15-06000-0067

	1. DWV (stack/15min) - OK H2O (50#/15min) - OK
	2. Original permit appears to be expired.
	3. Will perform framing once original permit is renewed.

INSTRUCTIONS: Complete Above, then call for framing inspection.

NEXT INSPECTION:

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

amber.green @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506