

KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-14-00675	OWNER'S NAME:	MONIE
DATE:	10/28/2014	TYPE:	Footings
TIME STARTED:	1:32 PM	INSPECTOR:	Amber Green
	20-14-19010-0008		

1. Footings are suppose to be 16" x 10".		
2. 42" x 42" x 10" spread footings are missing.		
3. Bolts for HDU hold downs are missing.		

INSTRUCTIONS: Complete Above, Re-Call Inspection. DO NOT POUR.

NEXT INSPECTION: RE-INSPECTION

RE-INSPECTION FEE DUE? NO

YES

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

amber.green @co.kittitas.wa.us

\$

• INSPECTION REQUEST LINE: <u>www.co.kittitas.wa.us/cds/request.asp</u> or 509-962-7694 • 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506