



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-14-00675      OWNER'S NAME: MOINE  
DATE: 11/13/2014      TYPE: Slab plumbing  
TIME STARTED: 11:02 AM      INSPECTOR: Amber Green  
MAP NUMBER: 20-14-19010-0008

	1. Plumbing not on test for inspection.

INSTRUCTIONS: Either 10 stack of water or 5 lbs of air for test. Systems must be on test for inspection.  
Re-Call

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE? ☒ NO ☐ YES \$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ amber.green @co.kittitas.wa.us

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •  
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506