



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00710

OWNER'S NAME: CASCADE VIEW INC

DATE: 3/12/2015

TYPE: Frame-Plumb-Mech

TIME STARTED: 9:40 AM

INSPECTOR: Lou Whitford

MAP NUMBER: 18-18-27071-0142

1. OK TRUSSES
2. OK FRAMING
3. RETEST PLUMBING AT INSULATION - NOT HOLDING
4. OK MECHANICAL ROUGH-IN

INSTRUCTIONS: VERIFY UNFINISHED BASEMENT USE. MUST INSULATE FLOOR WITH R-30 AND SHEET ROCK LID OR SECURE A CHANGE OF USE PERMIT TO MAKE HABITABLE SPACE.

NEXT INSPECTION: RE-INSP PLUMB TESTS. INSULATION

RE-INSPECTION FEE DUE? NO YES \$ _____
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ lou.whitford @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506