## **INSPECTION REPORT**

**PERMIT NUMBER:** 

BP-14-00710

OWNER'S NAME: CASCADE VIEW INC

Frame-Plumb-Mech

DATE:		3/24/2015	TYPE:	Frame-Plumb-Mech	
TIME STARTED:		10:37 AM	INSPECTOR:	Justin Bennett	
MAP NUMBER:		18-18-27071-0142			
	1. Waste	on stack - Ok			
	2. Supply @ 78#/15 min - Ok				
	3. Mechanical Ok				
	4. Install stair framing per plan or provide engineer fix				
INSTRUCTIONS: Ok to insulate/leave stair fix accessible for inspection/Make correction above or provide engineer fix					
NEXT INSPECTION: Insulation					
RE-INSPECTION FEE DUE? VES \$					
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION					
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:					
	justin.bennett @co.kittitas.wa.us				
• INSPECTION REQUEST LINE: <a href="www.co.kittitas.wa.us/cds/request.asp">www.co.kittitas.wa.us/cds/request.asp</a> or 509-962-7694 • 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506					