

KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-14-00716	OWNER'S NAME:	RUBIN
DATE:	6/30/2015	TYPE:	Multiple (see notes)
TIME STARTED:	10:49 AM	INSPECTOR:	Jessica Contratto
	18-17-34010-0002		

 1. tunnel grade beams- no rebar in plans. Rebar added by contractor

INSTRUCTIONS: ok to pour. Continue grade beams as currently formed for length of run

NEXT INSPECTION:

RE-INSPECTION FEE DUE?

V NO

YES

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

iessica.contratto @co.kittitas.wa.us

\$

• INSPECTION REQUEST LINE: <u>www.co.kittitas.wa.us/cds/request.asp</u> or 509-962-7694 • 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506