



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00752

OWNER'S NAME: SUNCADIAVION1LLC

DATE: 4/28/2015

TYPE: Exterior shear

TIME STARTED: 11:09 AM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-15-29051-0071

	1. All Exterior Posts Non Pressure Treated Need to Remain above Grade. Cannot Contact Concrete Porch Pad.
	2. Detail Required for Street Facing Garage wall Footings. Need for Revision will be Determined Upon Receipt of Detail.
	3. Exterior Shear OK.
	4. Interior Shear OK.

INSTRUCTIONS: OK to Cover Exterior

NEXT INSPECTION: Plumb/Mech

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506