



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00752

OWNER'S NAME: SUNCADIAVION1LLC

DATE: 5/27/2015

TYPE: Mechanical and plumbing

TIME STARTED: 1:55 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-15-29051-0071

1. Gas Line OK. 30#/15min.
2. Supply OK. Live.
3. DWV OK. 5#/15min.
4. Stutor OK Due to Framing Above.
5. Supply/Return Air OK.
6. Bath Fans Duct Not Connected.

INSTRUCTIONS: OK to Call for Framing.

NEXT INSPECTION: Framing

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506