

KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## **INSPECTION REPORT**

PERMIT NUMBER:	BP-14-00752	OWNER'S NAME:	SUNCADIAVISION1 LL
DATE:	1/13/2016	TYPE:	Final
TIME STARTED:	1:14 PM	INSPECTOR:	Justin Bennett
MAP NUMBER:	20-15-29051-0071		

1. Blower Door Ok			
2. Fireplace operation could not be verified			
3. Provide containment pan under Water Heater per plan review comments Dwg A4			
4. Maintain fire separation at Mechanical Nook (top and bottom)			
5. Provide Energy Credit Worksheet for Energy Code requirements			
6. Maintain fire separation @ garage opener wiring in garage			
7. Provide means to open floor access to verify insulation			
8. Provide fire rating specs on wash box in laudry room (fire seperation wall @ garage)			
9. Range Ok			
10. Mechanical Ok			
11. Plumbing Ok			
12. Verify L&I final has been completed			
13. Fire alarm/CO Ok			
INSTRUCTIONS: Complete items above			
· · ·			
NEXT INSPECTION: Re-Final			
RE-INSPECTION FEE DUE? VINO YES \$			
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:			
iustin.bennett @co.kittitas.wa.us			
• INSPECTION REQUEST LINE: <u>www.co.kittitas.wa.us/cds/request.asp</u> or 509-962-7694 •			
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506			



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## **INSPECTION REPORT**

PERMIT NUMBER:	BP-14-00752	OWNER'S NAME:	SUNCADIAVISION1 LL
DATE:	1/13/2016	TYPE:	Final
TIME STARTED:	1:14 PM	INSPECTOR:	Justin Bennett
MAP NUMBER:	20-15-29051-0071		

	Page 2			
	14. Kitchen range hood Ok			
	15. Electrical outlets in garage must be surface mount to maintain fire seperation			
INSTRUCTIONS: Complete items above				
NEXT INSPECTION: Re-Final				
RE-INSPECTION FEE DUE? VIC YES \$				
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION				
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:				
	iustin.bennett @co.kittitas.wa.us			
	<ul> <li>INSPECTION REQUEST LINE: <u>www.co.kittitas.wa.us/cds/request.asp</u> or 509-962-7694 </li> <li>411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506</li> </ul>			