INSPECTION REPORT

PERMIT NUMBER:	BP-14-00754	OWNER'S NAME:	NEW SUNCADIA LLC
DATE:	6/1/2015	TYPE:	Framing
TIME STARTED:	2:56 PM	INSPECTOR:	Justin Bennett
MAP NUMBER:	20-14-13050-0015		
1. Corrections not complete			
2. Complete draftstop @ fireplace			
3. Complete installation of nuts @ ceiling beams at beams			
4. Complete HDU installation			
5. Gas piping @ 13# - Must be at 15# for 15 mins			
6. Install truss bracing per plans			
INSTRUCTIONS: Complete corrections/Re-inspection			
NEXT INSPECTION: Re-inspection			
RE-INSPECTION FEE DUE? YES \$			
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:			
iustin.bennett @co.kittitas.wa.us			
 INSPECTION REQUEST LINE: <u>www.co.kittitas.wa.us/cds/request.asp</u> or 509-962-7694 ◆ 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 ◆ Main Office Line: 509-962-7506 			