## **INSPECTION REPORT**

PERMIT NUMBER: BP-14-00754 OWNER'S NAME: NEW SUNCADIA LLC

DATE:		6/9/2015	TYPE:	Re-inspection	
TIME STARTED:		1:14 PM	INSPECTOR:	Justin Bennett	
MAP NUMBER:		20-14-13050-0015			
1	1. Corrections Ok				
	Gas @ 15#/15 mins - Ok				
		Fireplace rough-in Ok			
	4. Ok to insulate				
INSTRUCTIONS: Ok to insulate					
NEXT INSPECTION: Insulation					
RE-INSPECTION FEE DUE? VES \$					
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION					
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:					
	iustin.bennett @co.kittitas.wa.us				
<ul> <li>INSPECTION REQUEST LINE: <u>www.co.kittitas.wa.us/cds/request.asp</u> or 509-962-7694 ◆</li> <li>411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 ◆ Main Office Line: 509-962-7506</li> </ul>					
TIT IV. NODY STICE, SUICE 2, EIICHSDUIG, WAS 30320 - Wall Office Line. 303-302-7300					