INSPECTION REPORT

TYPE:

PERMIT NUMBER:

DATE:

BP-14-00754

7/21/2015

OWNER'S NAME:

NEW SUNCADIA LLC

Insulation

TIME STARTED:		9:07 AM	INSPECTOR:	Jeremy Haberman
MAP NUMBER:		20-14-13050-0015		
	1 QED In	vaulation OK		
	1. SFR Insulation OK.			
	2. Garage Not Insulated at Time of Inspection.			
	3. Garage Storage Attic Exceeds 200 Sq. Ft. Maximum for Ladder Access.			
INSTRUCTIONS: OK to Cover SFR. Complete Insulation in Garage/ Install Stairs or Remove Sheeting from Garage Attic and Call for Re Inspection. DO NOT COVER GARAGE.				
Hom Garage Auto and Gair for the inspection. DO NOT GOVER GARAGE.				
NEXT INSPECTION: Re Inspect.				
RE-INSPECTION FEE DUE? NO YES \$				
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION				
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:				
jeremy.haberman @co.kittitas.wa.us				
• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 • 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506				