



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00754 OWNER'S NAME: NEW SUNCADIA LLC
 DATE: 11/20/2015 TYPE: Final
 TIME STARTED: 11:36 AM INSPECTOR: Jeremy Haberman
 MAP NUMBER: 20-14-13050-0015

1. Gas Line Not Terminated at Outdoor Firepit??
2. 220v. Electrical Wires Stub Out of Exterior Not Terminated.
3. Exerior Siding Not Complete at Entry.
4. Unable to Verify Fireplace Function at Great Room.
5. 220v. Electrical Wires Stub Out of Laundry Not Terminated.
6. Electrical Trim Not Complete at Great Room Ceiling.
7. PERMIT SET DRAWING, ENERGY CALCULATIONS, SEWER LETTER, ACCESS PERMIT
8. Electrical Not Complete in Garage Throughout.
9. Garage Attic Access Ladder Not Functional. Access Required for Use Verification.
10. Unable to Verify If Fire Marshall Final has been Completed??

INSTRUCTIONS: Make Corrections Above. Call For Reinspection. Request Replacement Permit Card if Lost.

NEXT INSPECTION: Final

RE-INSPECTION FEE DUE? NO YES \$ _____
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman @co.kittitas.wa.us

• **INSPECTION REQUEST LINE:** www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506