



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00754 OWNER'S NAME: NEW SUNCADIA
 DATE: 11/24/2015 TYPE: Final
 TIME STARTED: 11:10AM INSPECTOR: Jeremy Haberman
 MAP NUMBER: 20-14-13050-0015

1. Siding Not Complete at Entry.
2. NOTE: GAS LINE WILL NOT BE RUN TO FIRE PIT. CONTRACTOR OF FUTURE OWNER MIT GAS LINE AND FIREPLACE APPLIANCE.
3. Fire Marshall Final OK.
4. Sewer Connection Letter Not Onsite.
5. Blower Door Test Not Complete.
6. Non Combustible Hearth In Front of Fireplace Not Complete.
7. Energy Credits Not Verified.

INSTRUCTIONS: Make Corrections Above. PAY REINSPECTION FEE.

NEXT INSPECTION: Final Re Inspect

RE-INSPECTION FEE DUE? NO YES \$ 65.00

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman@co.kittitas.wa.us

• **INSPECTION REQUEST LINE:** www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506