



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00757 OWNER'S NAME: ZAHARIAS
DATE: 3/30/2015 TYPE: Slab plumbing
TIME STARTED: 12:49 PM INSPECTOR: Justin Bennett
MAP NUMBER: 19-18-08000-0018

	1. Under floor plumbing @ 5#/15 mins - Ok
	2. Ok to Pour

INSTRUCTIONS: Ok to pour

NEXT INSPECTION: Framing

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

justin.bennett @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506