



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00757

OWNER'S NAME: ZAHARIAS

DATE: 5/21/2015

TYPE: Rough-in plumbing

TIME STARTED: 1:11 PM

INSPECTOR: Jessica Contratto

MAP NUMBER: 19-18-08000-0018

	1. DWV at 5#-ok
	2. H2O at 80#-ok
	3. slab not insulated in habitable area per plan, according to owner
	4. range marked on plans as omitted. Range electrical is currently installed

INSTRUCTIONS: need to discuss options for uninsulated area. plumbing ok

NEXT INSPECTION: frame/ mechanical

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506