INSPECTION REPORT

BP-14-00759

PERMIT NUMBER:

OWNER'S NAME: CASCADE VIEW INC

DATE:		3/30/2015	TYPE:	Re-inspection	
TIME STARTED:		12:11 PM	INSPECTOR:	Jessica Contratto	
MAP NUMBER:		18-18-27071-0141			
	1. DWV a	I. DWV at 8#-ok			
	2. insulat	. insulation ok			
INSTRUCTIONS: ok to cover. See fresh air with damper at attic unit at final. Also see fresh air inlets at main floor in habitble rooms at final					
NEXT INSPECTION: final					
RE-INSPECTION FEE DUE? VES \$					
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION					
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:					
	jessica.contratto @co.kittitas.wa.us				
• INSPECTION REQUEST LINE: <u>www.co.kittitas.wa.us/cds/request.asp</u> or 509-962-7694 •					