## **INSPECTION REPORT**

PERM	T NUMBER:	BP-14-00765	OWNER'S NAME:	HALL	
DATE:		5/22/2015	TYPE:	Framing	
TIME STARTED:		11:32 AM	INSPECTOR:	Jessica Contratto	
MAP NUMBER:		20-15-20058-0135			
	1. engineer	ngineer approval for connectors			
	2. stamped truss sheets not on site				
	3. missing CS18 straps in numerous locations				
	4. bedroom fireplace chimney still touching back of tv nook				
	5. framing ok				
	6. complete draftstop at upstairs duct chase				
INSTRUCTIONS: ok to insulate, see corrections					
NEXT INSPECTION: insulation					
RE-INSPECTION FEE DUE? V NO YES \$					
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION					
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:					
	iessica.contratto @co.kittitas.wa.us				
<ul> <li>INSPECTION REQUEST LINE: <a href="www.co.kittitas.wa.us/cds/request.asp">www.co.kittitas.wa.us/cds/request.asp</a> or 509-962-7694</li> <li>411 N. Ruby Street, Suite 2, Ellensburg, WA 98926</li> <li>Main Office Line: 509-962-7506</li> </ul>					