



KITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00765 OWNER'S NAME: HALL
DATE: 9/29/2015 TYPE: Final
TIME STARTED: 2:33 PM INSPECTOR: Jeremy Haberman
MAP NUMBER: 20-15-20058-0135

1. Electrical Trim Not Complete Throughout.
2. Unable to Verify Bath Exhaust/Kitchen Exhaust Due to Electrical??
3. HVAC Supply Trim Not Complete
4. Sewer/Access OK.
5. Plumbing Final OK.
6. Fireplace Final OK.
7. Tension Hinge on Garage MAn Door.
8. Range Not Installed.
9. Exterior Heat Pump Not Connected.
10. WUIC Final Not Complete.
11. Fire Sprinkler Final Not Complete.
12. Fire Sprinkler Trim Rings Missing.
13. Verify Energy Credits Once HVAC is Complete.

INSTRUCTIONS: Complete Above.

NEXT INSPECTION: Final

RE-INSPECTION FEE DUE? NO YES \$ _____
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00765

OWNER'S NAME: HALL

DATE: 9/29/2015

TYPE: Final

TIME STARTED: 2:33 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-15-20058-0135

	Page 2
	14. NOTE: Hot Tub Final OK. ON Seperate Permit #BP-15-00702

INSTRUCTIONS: Complete Above.

NEXT INSPECTION: Final

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506