## **INSPECTION REPORT**

PERMIT NUMBER:		BP-14-00788	OWNER'S NAME:	DW FINANCIAL
DATE:		7/9/2015	TYPE:	Framing
TIME STARTED:		10:53 AM	INSPECTOR:	Justin Bennett
MAP NUMBER:		20-15-20058-0099		
	1. Provide revised truss sheets stamped by the engineer (revised sheets not stamped)			
	2. Provide 6x6 at stairs off entry as shown on sheet 4 (clouded)			
	3. Provide hangers @ stairs as shown on detail 23/2.1			
	4. Provide lag bolts in knee braces per detail 20 & 21 /2.1			
	5. Provide A35's @ gable trusses per detail 17/2.1			
	6. Provide LUS26 @ gable framing per detail 18/2.1			
	7. Install A35's as indicated on sheet 5			
	8. Install RBC's as indicated on sheet 5			
	9. Install RBC's as indicated on sheet 7			
	10. Fireplace framing not complete			
	11. Provide connection detail for the post and beams @ the entry foyer off the Great Room			
INSTRUCTIONS: Complete corrections above/Re-Inspection				
NEXT INSPECTION: Re-Inspection				
RE-INSPECTION FEE DUE? YES \$				
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION				
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:				
<u>iustin.bennett</u> @co.kittitas.wa.us				
<ul> <li>INSPECTION REQUEST LINE: <a href="www.co.kittitas.wa.us/cds/request.asp">www.co.kittitas.wa.us/cds/request.asp</a> or 509-962-7694</li> </ul>				

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506