



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00788

OWNER'S NAME: DW FINANCIAL

DATE: 1/25/2016

TYPE: Final

TIME STARTED: 11:46 AM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-15-20058-0099

1. Blower Door Test OK per Energy Requirements.
2. Outdoor Firepit Covered on New Permit Number BP-16-000024.
3. Final OK.

INSTRUCTIONS:

NEXT INSPECTION:

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: jeremy.haberman @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506